

# Sanitary Sewer Notification

**Address:** 112 Terrace Hall Ave

**City:** Burlington

**State:** MA

**Zip Code:** 01803

**SMH ID:** Terrace Hall Ave Sewer Pump Station

**Water Bodies and Municipalities Directly Affected:** Vine Brook, Burlington, Bedford, Billerica, Wilmington

**Event Description:** Per intermunicipal SOP with Woburn, when Woburn has an SSO in the sewer interceptor that Burlington sewer flows through, Burlington will bypass sewer flows at the Terrace Hall Ave Sewer Pump Station untreated into the Vine Brook to alleviate the magnitude of the SSO occurring in Woburn. This began at ~7:30AM on 1/10/24. It is unknown how long the event will occur. More updates will be made as required.

**Event Start Date & Time:** 1/10/2024 7:30 AM

**Is the Event Ongoing?** Yes

**If No, Event Stop Date & Time:**

**Estimated Volume of SSO:** ~1,500 GPM

**Advisement:** The discharge or overflow consists, or likely consists, of untreated or partially treated sewerage and waste. The public is advised to avoid contact with these water bodies for 48 hours after the discharge or overflow ceases due to increased health risks from bacteria and other pollutants. For additional questions, please contact the Burlington Department of Public Works - Engineering Division at 781-270-1640.